

4-30-91  
12-3.8rs



GE Industry  
Sales & Services

April 30, 1991

Mr. Dan Peters  
ASH GROVE CEMENT COMPANY  
3801 E. Marginal Way  
Seattle, WA 98314

Subject: SAMPLE TEST RESULTS  
General Electric Tracking No. 22286

Enclosed are the results of the swab samples taken by General Electric Crew from the 10' x 20' concrete pad in the "Raw Mill".

Please keep this information with your permanent records.

If you have any questions please feel free to call (503) 221-5098.

Thank you,

*Shirlee K. Porter*  
Shirlee K. Porter  
Facility Supervisor  
Portland, Oregon

att *SK*  
SKP/jr

RECEIVED  
MAY - 3 1991

AGCW - SEATTLE

USEPA SF



1261628

AGC2F000060



April 24, 1991  
Log #GE910422-C7  
PO #073-22286-7

Attention: Shirlee Porter  
General Electric Company  
PCB Facility  
2535 NW 28th  
Portland, OR 97210

Samples Collected: 04/19/91  
Samples Received: 04/22/91

Analysis Performed: Polychlorinated Biphenyls (PCBs) in swab by  
modified EPA Method 8080, GC/ECD.

SAMPLE ID	PCB	AROCLOR
-----	---	-----
Sample 1	ND	--
Sample 2	ND	--
Sample 3	ND	--
Sample 4	ND	--
Sample 5	ND	--
Sample 6	ND	--
Sample 7	ND	--

Detection Limit: 0.8

Results expressed as  $\mu\text{g}/\text{swab}$

ND means none detected at or above the detection limit listed.

Sincerely,

Victor A. Perry,  
Quality Assurance

Sincerely,

Renee Chauvin,  
Technical Director

RJC/lws

This report is for the sole and exclusive use of the client. Samples are retained  
a maximum of 15 days from the report date, or until the maximum holding time expires.

COFFEY LABORATORIES, INC.

12423 N.E. Whitaker Way • Portland, OR • 97230 • (503) 254-1701 • FAX (503) 254-1450

AGC2F000061

ANNUAL PCB DOCUMENT LOG - 1989

=====

PERIOD COVERED: JANUARY 1, 1989 - FEBRUARY 5, 1990

LOG PREPARED: FEBRUARY 4, 1991

ASH GROVE CEMENT WEST, INC

3801 E. MARGINAL WAY S.

SEATTLE, WA 98134

EPA ID #: WAD009249616

DISPOSAL RECORD

=====

MANIFEST	DESCRIPTION	REMOVED SERVICE	PLACED TRANSPORT	DESTROY/ DISPOSE	TOTAL WT. (KG)
21665	XFRM SN. PCR-61541	03/15/89	03/15/89	03/28/89	8182
21665	BULK PCB FLUID 955.8 GAL	03/15/89	03/15/89	04/26/89	3255
193MA	XFRM SN. F963361	08/19/89	08/19/89	09/05/89	1842
193MA	XFRM SN. F963294	08/19/89	08/19/89	09/01/89	1803
193MA	XFRM SN. F963295B	08/19/89	08/19/89	09/05/89	2087
193MA	XFRM SN. F963795A	08/19/89	08/19/89	09/05/89	2132
193MA	PCB FLUID 5.0 GAL	08/19/89	08/19/89	12/08/89	23
193MA	PCB FLUID 5.0 GAL	08/19/89	08/19/89	12/08/89	23
193MA	PCB FLUID 8.0 GAL	08/19/89	08/19/89	12/08/89	39
193MA	PCB FLUID 9.0 GAL	08/19/89	08/19/89	12/08/89	41
193MA	PCB FLUID 555.0 GAL	08/19/89	08/19/89	06/03/90	3202

IN SERVICE RECORD

=====

NO PCBS EXISTED AT THE SITE AT THE END OF THE YEAR.

ANNUAL PCB DOCUMENT LOG - 1990

=====

PERIOD COVERED: FEBRUARY 6, 1990 - DECEMBER 31, 1990

LOG PREPARED: FEBRUARY 4, 1991

ASH GROVE CEMENT WEST, INC

3801 E. MARGINAL WAY S.

SEATTLE, WA 98134

EPA ID #: WAD009249616

DISPOSAL RECORD

=====

NO PCBs EXISTED AT THE SITE DURING THE YEAR.

IN SERVICE RECORD

=====

NO PCBs EXISTED AT THE SITE AT THE END OF THE YEAR.